GOVERNOR'S MANSION HVAC UPGRADE DFCM # 06183310

OFCM DE: (Fee A.E: Attach and fil							:++~1)		
(ree A.E. Allach and III	ı ın aş	philoaple	adia for	each	araw	ing subm	iliai)		
Applicable Codes: International Building Code Planning & Design Criteria to Prevent Architectural Barriers for the Aged and the Physically Handicapped.	<u>Ye</u> 20	<u>ear</u> 003		onal Pl IES Ene	lumb ergy		e	<u>rear</u> 2003 2003 1999 2002	
A. Occupancy and Group : B / S-1				_			-		
Change in Use : Yes No 🗹		Mixed	Occupar	ıcy :	Yes_	✓ No			
B. Type of Construction (Circle) $\frac{1}{F.R.}$	<u>Ⅱ</u> F.R.	<u>II</u> 1 HR.	$\frac{\mathbb{I}}{\mathbb{B}}$	 1 H	ĪR.		IV H.T.	1	V HR. N
C. Location on Property : F.R. Ext. Walls (Hrs.):	N.R.	Ext.	Wall (Openi Eacl	ing(s) Pro n Occupar	tection ncy	(Hrs.) <u>N.R.</u>
D. Occupancy separation required (Hrs.): Sprinklered: Indicate Yes or No		B/R-2=	=2 HR	-		·	- -		
Stories : 1 or multiple									
 a. Actual Area²(ft) b. Basic allowable area : c. Allowable Area Increase due to side yards: N 		I	SF ea (f ²)	-	%	Area (ft	- -) -	<u></u> %	Area (ft)
				-			-		
d. Side yard area incredse (ft): Accumulative sub—total (b=d): Sprinkler: area increase (x3 single)		N.	A	- - -			-		
(x 2 multi) e. Total Allowable Area for a single story:		N.	Α	_			_		
x 2 for multi-story building:f. Ratio = a/e (Actual divided by allowable)				-			-		
E. Fire—Resistive Requirements	(Hrs.)): (1 H	r., 2Hr., 3	3Hr., 4	Hr.,	N. H.T.)			
Exterior Bearing Walls:	N		Floors	s – Ce	iling	Floors	_		N
Interior Bearing Walls:	N N			- Ce	-				N ND
Exterior Non-bearing Walls: Structural Frame:	N N			or Doc Enclos		nd Windov	WS		NR 1 HR



State of Utah—Department of Administrative Services

DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

4110 State Office Building / Salt Lake City, Utah 84114 / 538-3018



DRAWING INDEX:

M-000 TITLE SHEET

M-001 MECHANICAL GENERAL NOTES AND LEGEND MD-101 MECHANICAL DEMOLITION FLOOR PLAN

ME-101 MECHANICAL FLOOR PLAN ME-501 MECHANICAL DETAILS

ME-601 MECHANICAL SCHEDULES



		MECHANICAL	LEGEN	ND	
SYMBOL	ABR.	DESCRIPTION	SYMBOL	ABR.	DESCRIPTION
GENERAL	TERMI	NOLOGY	AIR SIDE	1	
A		- SECTION LETTER DESIGNATION	₩₽		EXISTING AIR DUCT TO BE REMOVED
ME-101	•	- SECTION DRAWN ON THIS SHEET	\-\\ \=\		EXISTING AIR DUCT TO REMAIN
		- DETAIL NUMBER DESIGNATION	\hookrightarrow		NEW AIR DUCT
(A2)		CORRESPONDING WITH GRID LOCATION	江草		RECT. TO RECT. AIR DUCT TAKE-OFF
AN		- MECHANICAL EQUIPMENT	八 草		RECT. TO RND. AIR DUCT TAKE-OFF
1		DESIGNATION - EQUIPMENT ITEM DESIGNATION	江草		RND. TO RND. AIR DUCT TAKE-OFF
D-1		REGISTER, GRILLE OR DIFFUSER	\ \ \H		RECT. TAKE-OFF AT END OF MAIN
CFM		DESIGNATION WITH BALANCING CFM LISTED BELOW	<u> </u>		BURIED OR UNDER FLOOR DUCT
		GRILLE, OR LOUVER DESIGNATION	Simoning		FLEXIBLE AIR DUCT
R-1		WHERE BALANCING NOT REQUIRED			LINED DUCT
\bigwedge		REVISION DESIGNATOR AND NUMBER			VANED ELBOW
$\overline{\langle 1 \rangle}$		KEY NOTE DESIGNATOR AND NUMBER			RADIUS ELBOW
•	POC	POINT OF CONNECTION	₩ □		CONCENTRIC DUCT TRANSITION
	POR	POINT OF REMOVAL			ECCENTRIC DUCT TRANSITION
	FOR				
AFF		ABOVE FINISHED FLOOR			FLEXIBLE DUCT CONNECTION
AP		ACCESS PANEL			VOLUME DAMPER
မူ EL.		CENTER LINE ELEVATION			SUPPLY AIR DIFFUSER RETURN AIR, FRESH AIR, AND
VV. ELEV.		INVERT ELEVATION	Ø		TRANSFER AIR
GC		GENERAL CONTRACTOR	Ø		CEILING MOUNTED EXHAUST FAN OR EXHAUST GRILLE
МС		MECHANICAL CONTRACTOR			RETURN OR OUTSIDE AIR DUCT UP
CC		CONTROL CONTRACTOR	├▼ ├▼		SUPPLY DUCT UP
EC		ELECTRICAL CONTRACTOR			EXHAUST AIR INTAKE UP
FPC		FIRE PROTECTION CONTRACTOR			RETURN OR OUTSIDE AIR DUCT DOWN
NIC		NOT IN CONTRACT			SUPPLY DUCT DOWN
NTS		NOT TO SCALE			EXHAUST DUCT DOWN
VCP		VITRIFIED CLAY PIPE	├७ १७		ROUND DUCT UP
С		COMMON	(I) (H)		ROUND DUCT DOWN
NC		NORMALLY CLOSED	__\		RAISE DUCT UP
NO		NORMALLY OPEN			LOWER DUCT DOWN
110		THORWINGET OF EIN			FLEXIBLE DUCT CONNECTION
					PARALLEL BLADE DAMPER
					OPPOSED BLADE DAMPER
					HUMIDIFIER
					AIRFLOW MEASURING STATION
					FILTER BANK
					COIL
				AP	ACCESS PANEL
					EXISTING EQUIPMENT TO BE REMOVE
					EXISTING EQUIPMENT TO REMAIN
					NEW EQUIPMENT
			M	MVD	MOTORIZED VOLUME DAMPER
			BD	BD	BACKDRAFT DAMPER
			F	FD	FIRE DAMPER
			R	RD	RADIATION TYPE FIRE DAMPER
			\$	SD	SMOKE DAMPER
			F>	FS	FIRE & SMOKE DAMPER
			(T)	T'STAT	WALL MOUNTED THERMOSTAT
					WALL MOUNTED TEMP. SENSOR
				ПіСТУТ	
			(H)		WALL MOUNTED FIRESTAT
				F'STAT	
			SA		SUPPLY AIR
			RA		RETURN AIR
			EA		EXHAUST AIR
			OA		OUTSIDE AIR
			MA		MIXED AIR
			FA		FRESH AIR
1		П	RF	2	

² RELIEF AIR

MECHANICAL GENERAL NOTES:

MECHANICAL INFORMATION IS NOT LIMITED TO THE MECHANICAL DRAWINGS. CONTRACTOR SHALL BE RESPONSIBLE FOR INFORMATION ON ALL OTHER CONSTRUCTION DOCUMENTS INCLUDING DRAWINGS BY

OTHER DISCIPLINES AND SPECIFICATIONS.

A - EACH DRAWING SHEET AND THE SPECIFICATIONS HAVE BEEN PREPARED TO SUPPLEMENT EACH OTHER AND THEY SHALL BE INTERPRETED AS AN INTEGRAL UNIT WITH ITEMS SHOWN AND NOTED ON ONE AND NOT THE OTHER BEING FURNISHED AND INSTALLED AS THOUGH SHOWN AND CALLED OUT IN ALL PLACES.

B - THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR THE INSTALLATION OF THE SYSTEMS ACCORDING TO THE TRUE INTENT AND MEANING OF THE CONTRACT DOCUMENTS.

C - THE CONTRACTOR SHALL INSTALL ALL EQUIPMENT WITH PROPER SERVICE ACCESS AND CLEARANCES ACCORDING TO MANUFACTURERS RECOMMENDATIONS. THE CONTRACTOR SHALL REVIEW SUPPLIERS BID PACKAGES FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS, SCHEDULES, AND DESIGN INTENT (ALL EQUIPMENT AND METHODS). THE CONTRACTOR SHALL REMOVE AND REINSTALL CORRECTLY AT HIS OWN EXPENSE ANY EQUIPMENT NOT IN COMPLIANCE.

D - THE CONTRACTOR SHALL CONSULT MANUFACTURERS INSTALLATION INSTRUCTIONS FOR SIZES, METHODS, ACCESSORIES, AND CLEARANCES IN SPACE AVAILABLE PRIOR TO BIDDING PROJECT.

E - ANYTHING NOT CLEAR OR IN CONFLICT WILL BE EXPLAINED BY MAKING APPLICATION TO THE ENGINEER IN WRITING.

ANY AND ALL ALTERATIONS TO THE SYSTEM SHOWN SHALL BE THE RESPONSIBILITY OF THIS CONTRACTOR. ARCHITECT SHALL BE NOTIFIED IN WRITING PRIOR TO CHANGES.

CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND LOCATIONS.

THE WORKING DRAWINGS ARE DIAGRAMMATIC. THEY DO NOT SHOW EVERY OFFSET, BEND, OR ELBOW NECESSARY FOR THE COMPLETE INSTALLATION IN THE SPACE PROVIDED. ALL LOCATIONS FOR MECHANICAL EQUIPMENT SHALL BE FIELD VERIFIED AND COORDINATED WITH ALL DRAWINGS. THE CONTRACTOR SHALL PROVIDE OR COORDINATE WITH THE GENERAL CONTRACTOR PROVISIONS FOR BLOCKOUTS OR CORE DRILLS THROUGH STRUCTURE.

THE INSTRUCTION TO "PROVIDE" ALSO INCLUDES INSTALLATION.

MECHANICAL CONTRACTOR SHALL PROVIDE AND INSTALL SMOKE AND FIRE DAMPERS AS REQUIRED BY LOCAL CODES AND AUTHORITIES.

SHEET METAL DUCT SIZES SHOWN ON DRAWINGS ARE FREE AREA DIMENSIONS.

PROVIDE AND INSTALL BALANCING DAMPERS IN ALL SUPPLY AND EXHAUST AIR BRANCH DUCTS. BALANCE TO CFM SHOWN ON PLAN.

PROVIDE TURNING VANES IN ALL ELBOWS OF RECTANGULAR DUCT.

THE CONTRACTOR SHALL ASSUME ALL RESPONSIBILITY IN HANDLING AND DISPOSING OF REFRIGERANTS, OILS, ETC. ALL SUCH MATERIALS SHALL BE HANDLED, DISPOSED, AND USED ON ACCORDANCE WITH ALL LOCAL, STATE, AND FEDERAL LAWS.

THE MECHANICAL CONTRACTOR SHALL VERIFY MOTOR VOLTAGES WITH THE ELECTRICAL DRAWING BEFORE ORDERING MOTORIZED EQUIPMENT AND CONTROLS. MOTOR NAMEPLATE VOLTAGE SHALL BE NEMA STANDARD 200 VOLT FOR 208 VOLT, THREE PHASE SYSTEM AND SHALL BE NEMA STANDARD 230 VOLT FOR 240 VOLT, THREE PHASE, OR SINGLE PHASE SYSTEM. STARTER HEATER INSTALLED SHALL BE COORDINATED WITH THE NAMEPLATE DATA.

C.F.M. LISTED IS ACTUAL AIR.

SUPPLIERS SHALL REVIEW ALL DRAWINGS AND THE SPECIFICATIONS PRIOR TO SUBMITTING PRICES TO THE CONTRACTOR. ALL QUESTIONS AND DISCREPANCIES SHALL BE BROUGHT TO THE ENGINEERS ATTENTION PRIOR TO BIDDING.

CONTRACTOR SHALL THOROUGHLY REVIEW AND SIGN SUBMITTALS FOR COMPLETENESS AND COMPLIANCE TO THE SPECIFICATIONS PRIOR TO ENGINEERS REVIEW. SUPPLIERS SHALL HIGHLIGHT OR MARK ALL INFORMATION REQUIRED TO SHOW COMPLIANCE TO THE SPECIFICATIONS. ALL REQUESTED EXCEPTIONS TO THE SPECIFICATIONS, OR SCHEDULES SHALL BE CLEARLY NOTED AND EXPLAINED. SUBMITTAL REVIEW AND ACCEPTANCE IS FOR DESIGN CONCEPT ONLY, AND DOES NOT AT ANY TIME RELIEVE THE CONTRACTOR OF RESPONSIBILITY TO MEET SPECIFICATIONS, CAPACITIES, OR DESIGN INTENT.

THE MECHANICAL INSTALLATION SHALL CONFORM TO THE 2003 EDITION OF THE IMC WITH UTAH ANNOTATIONS AND LOCAL AUTHORITY REQUIREMENTS.

State of Utah

Department of Administrative Services



Division of Facilities Construction & Management 4110 State Office Building Salt Lake City, Utah 84114 Phone: (801) 538 - 3018 Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC.
PROFESSIONAL MECHANICAL ENGINEERING 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC. These documents are protected under the United States 1978 copyright act. It is an exclusive work of original authorship. None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS

GOVERNOR'S MANSION HVAC REPLACEMENT

DFCM# 06182310

SALT LAKE CITY, UTAH

REVISION


MARK DATE

PROJECT	MANAGI WP	ER:		
DRAWN		٦		
I	STAFI	.		
CHECKE	DBY:			

2T M 07/28/06 WHW JOB NO.: 06017 SHEET TITLE

> **MECHANICAL GENERAL NOTES AND LEGEND**


M001



copyright act. It is an exclusive work of original authorship.


None of the pictorial, graphic, or technical charts or

ROJECT MANAGER: WP		
RAWN BY:		
STAFF		\
HECKED BY:	7/	
SLW		



MECHANICAL CHILLER **AREA PLAN**

SCALE: 1/4" = 1'



SHEET NOTES

- PROVIDE NEW SUPPLY DUCT FROM FAN COIL FC-1. BALANCE DIFFUSERS TO CFM SHOWN. ADDITIVE ALTERNATE #2 USE LARGER DIFFUSERS AND BALANCE CDM TO 25% MORE THAN SHOWN. SEE SCHEDULE SHEETS.
- PROVIDE NEW SUPPLY DUCT FROM EXISTING FAN COIL FC-5. BALANCE DIFFUSERS TO CFM SHOWN. ADDITIVE ALTERNATE #1 USE LARGER DIFFUSERS AND BALANCE CDM TO 50% MORE THAN SHOWN. SEE SCHEDULE SHEETS.
- PROVIDE NEW FRESH AIR PENTHOUSE. THIS CONTRACTOR SHALL HIRE AN APPROVED ROOFING CONTRACTOR (UTAH TILE AND ROOF) TO MAINTAIN ROOF WARRANTY TO PATCH AND SEAL COPPER ROOF.
- ADDITIVE ALTERNATE #1: REPLACE EXISTING FAN COIL UNIT FC-5 WITH NEW LARGER UNIT. SEE SCHEDULES. RE-CONNECT TO EXISTING DUCTWORK CONNECTIONS, DAMPERS, HOT WATER COILS, CHILLED WATER COILS, ETC. REPLACE 3/4" HOT WATER BRANCHES WITH 1" BRANCHES.
- ADDITIVE ALTERNATE #2: REPLACE EXISTING FAN COIL UNIT FC-1 WITH NEW LARGER UNIT. SEE SCHEDULES. RE-CONNECT TO EXISTING DUCTWORK CONNECTIONS, DAMPERS, HOT WATER COILS, CHILLED WATER COILS, ETC.
- 6 PROVIDE NEW RELIEF AIR PENTHOUSE. THIS CONTRACTOR SHALL HIRE AN APPROVED ROOFING CONTRACTOR (UTAH TILE AND ROOF) TO MAINTAIN ROOF WARRANTY TO PATCH AND SEAL COPPER ROOF. PROVIDE AUTOMATIC DAMPER, CONTROLLED BY ATTIC SPACE PRESSURE SENSOR.
- PROVIDE NEW OUTSIDE AIRDUCTS TO RETURNS FOR EACH SYSTEM. PROVIDE 3-POSITION MODULATING DAMPERS FOR ECONOMIZER, AND MINIMUM OUTSIDE AIR CONTROL.
- $\langle 8 \rangle$ PROVIDE RELIEF AIR DAMPER AT TOP OF RETURN DUCT. OPEN AND DISCHARGE INTO ATTIC.
- PROVIDE WATER SIDE ECONOMIZER. INSTALL WITH REQUIRED CLEARANCES AT SIDES, ENDS, AND OTHER EXISTING EQUIPMENT.
- 10 PROVIDE NEW PIPING AND ISOLATION VALVES FOR NEW WATERSIDE ECONOMIZER. TIE INTO EXISTING PIPING DOWNSTREAM OF EXISTING ISOLATION VALVES FOR CHILLER. PROVIDE NEW ISOLATION VALVES FOR CHILLER, DOWNSTRAM OF ECOMOMIZER TIE IN.
- (11) EXISTING CHILLED WATER AND HOT WATER PIPING SHALL REMAIN.

State of Utah

Department of Administrative Services



Division of Facilities Construction & Management 4110 State Office Building Salt Lake City, Utah 84114
Phone: (801) 538 - 3018 Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. ROFESSIONAL MECHANICAL ENGINEERING 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC.

These documents are protected under the United States 1978 copyright act. It is an exclusive work of original authorship None of the pictorial, graphic, or technical charts or

drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS

GOVERNOR'S MANSION HVAC REPLACEMENT

DFCM# 06182310

SALT LAKE CITY, UTAH

REVISION

MARK DATE

06017

Ì	'MANAGI WP	ER:		
RAWN	WP ^{BY:} STAFI			
RAWN	WP ^{BY:} STAFI			
RAWN HECKE	WP by: STAFI d by:	7		

MECHANICAL FLOOR PLAN


ME101

MECHANICAL FLOOR PLAN


				TRA	NSVERSE R	REINFORCING	G (1)
		MINIMUM			AT JO	INTS	
DIMENSION OF LONGEST SIDE, INCHES	SHEET METAL GAGE (ALL FOUR SIDES)	REINFORCING ANGLE SIZE AND MAXIMUM LONGITUDINAL SPACING BETWEEN TRANSVERSE JOINTS &/OR	MIN. H. IN.	DRIVE SLIP PLAIN S SLIP	HEMMED S SLIP	ALTER'NT BAR SLIP	REIN- FORCEL BAR SLIP
		INTERMEDIATE REINFORCING		RECOM- MENDED GAGE	RECOM- MENDED GAGE	RECOM- MENDED GAGE	RECOM- MENDED GAGE
UP THRU 12	26	NONE REQUIRED	1	26	26	24	24
13 - 18	24	NONE REQUIRED	1	24	24	24	24
19 - 30	24	1"X1"X1/8" @ 60 IN	1	_	24	24	24
31 - 36	22	1"X1"X1/8" @ 60 IN	1	-	-	22	22

1. TRANSVERSE REINFORCING SIZE IS DETERMINED BY DIMENSION OF SIDE TO WHICH ANGLE IS APPLIED.












BRANCH DUCT TAKE-OFF & DAMPER DETAIL












COIL CONNECTION DETAIL SCALE: NONE

State of Utah Department of Administrative Services



Division of Facilities Construction & Management 4110 State Office Building Salt Lake City, Utah 84114 Phone: (801) 538 - 3018 Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. OFESSIONAL MECHANICAL ENGINEERING 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC. These documents are protected under the United States 1978 copyright act. It is an exclusive work of original authorship. None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used

PROJECT NAME & ADDRESS

or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

GOVERNOR'S MANSION HVAC REPLACEMENT

DFCM# 06182310

SALT LAKE CITY, UTAH

REVISION

MARK DATE

OJECT MANAGER: WP	
RAWN BY: STAFF	
HECKED BY: SLW	
ATE: 07/28/06	
HW JOB NO.: 06017	

MECHANICAL DETAILS

ME501

	WATER ECONOMIZER SCHEDULE											
		MAX. OPER.		OPERATING CO	NDITIONS			ELEC	CTRIC	CAL		MANUFACTURER
SYMBOL	GPM	WT. LBS.	NET CAPACITY TONS	OUTDOOR AIR TEMP °F	WATER IN TEMP °F	WATER OUT TEMP °F	HP	VOLT	Ø	Hz	RPM	AND MODEL#
WE 1	50		40	35	55	45						TSI FC-48

DIFFUSER SCHEDULE

SYMBOL	TYPE	MAX CFM	FACE SIZE	NECK SIZE	CEILING TYPE	BLOW	PATTERN	SCHEDULE NOTES
D-1 CFM	CEILING	1000	24x24	24x24	HARD	3WAY		1,2,3,4

- 1. PROVIDE LAY-IN CEILING AND BORDER / MODULE AS REQUIRED. SEE ARCHITECTURAL CEILING PLANS.
- 2. MAXIMUM NC 25 AT CFM LISTED.
- 3. DIFFUSER SHALL HAVE A FULLY ADJUSTABLE AIR PATTERN.
- 4. DIFFUSER SHALL BE PRICE SMDA WITH SB90 SECTORIZING BAFFLE, OR EQUAL BY MANUFACTURERS LISTED IN SPECIFICATIONS.

REGISTER, LOUVER & GRILLE SCHEDULE

SYMBOL	TYPE	SERVICE	MAX CFM	NOMINAL SIZE	THROAT SIZE	CEILING TYPE	COMMENTS	SCHEDULE NOTES
R-1	CEILING	RA	2000	24"X24"	24"X24"	HARD	PRICE 595	1,2,3
PH-1	ROOF MOUNTED	FA	5600	52"X20"X22"	16"X48"	NA	COOK 16x48 GI	2,4,5,6,7
PH-2	ROOF MOUNTED	RF	5600	63"x41"x16"	16"X48"	NA	COOK 16x48 GR	2,4,5,6,7

REGISTER. LOUVER AND DIFFUSER SCHEDULE NOTES:

- 1. MAXIMUM NC = 25 @ MAXIMUM CFM NOTED.
- 2. SEE SPECIFICATIONS FOR APPROVED MANUFACTURERS.
- 3. PRIMED COAT FOR RIELD PAINTING.
- 4. KYNAR FINISH WITH COLOR SELECTED BY OWNER TO MATCH COPPER ROOF.
- 5. PROVIDE ALUMINUM BIRD SCREENS.
- 6. PROVIDE PENTHOUSE WITH A MINIMUM 8.0 SQUARE FEET FREE AREA.
- 7. PROVIDE WITH ROOFCURB. THE CONTRACTOR SHALL HIRE AN APPROVED ROOFING CONTRACTOR (UTAH TILE AND ROOF) TO CUT, PATCH, AND SEAL ROOF.

FAN COIL UNIT SCHEDULE

		FAN (2 SPEED)		COOLING COIL (4 ROW)				HEATING COIL (2ROW)								
SYMBOL	ROOMS SERVED	SCFM COOLING / HEATING	O.A. CFM	ESP	H.P.	MIN. REQ'D CAP. TOTAL MBH	MIN. REQ'D CAP. GPM	COND. ENT. EVAP. DB° F	CND. ENT. EVAP. WB° F	LAT DB/WB	МВН	MIN. GPM	EAT / LAT	EWT/LWT	MANUF. & MODEL #	SCHEDULE NOTES
FC 1	BALL ROOM	4400/2200	800	.75	1.5	165	31.5	80	67	56.4/55.5	267	14	60/105	180/150	MAGIC AIRE 180-HBAW	1,2,4
FC 5	BILLARD ROOM	2200/1100	400	.75	1.0	80	17	80	67	56.4/55.5	140	9.0	60/105	180/150	MAGIC AIRE 90-HBAW	1,2,3

ALTERNATE #2~

ALTERNATE #1-

- 1. SEE SPECIFICATIONS FOR OTHER APPROVED MANUFACTURES.
- 2. VOLTAGE 120/1/60
- 3. ADDITIVE ALTERNATE #1.
- 4. ADDITIVE ALTERNATE #2.

State of Utah
Department of Administrative Services



Division of Facilities Construction & Management 4110 State Office Building Salt Lake City, Utah 84114 Phone: (801) 538 - 3018 Fax: (801) 538 - 3267

Internet: http://www.dfcm.state.ut.us

CONSULTANTS



WHW ENGINEERING INC. PROFESSIONAL MECHANICAL ENGINEERING 1354 East 3300 South Suite 200 SALT LAKE CITY, UTAH 84106 (801)466-4021, FAX 466-8536

COPYRIGHT NOTICE

ALL RIGHTS RESERVED © WHW ENGINEERING, INC. These documents are protected under the United States 1978 copyright act. It is an exclusive work of original authorship. None of the pictorial, graphic, or technical charts or drawings depicted may be reproduced by any method, mechanical, electronic, or otherwise; nor may they be used or re-used for any purpose without the express prior written permission of WHW Engineering, Inc.

PROJECT NAME & ADDRESS

GOVERNOR'S MANSION HVAC REPLACEMENT

DFCM# 06182310

SALT LAKE CITY, UTAH

MARK	DATE	REVISION

PROJECT MANAGER: WP DRAWN BY: STAFF CHECKED BY: SLW 07/28/06 WHW JOB NO.: 06017

> **MECHANICAL SCHEDULES**

ME601